

# User Guide DAT11188PN

## PROFINET IO SLAVE – 8 DIGITAL INPUTS AND 8 PNP OUTPUTS

### GENERAL INFORMATION

**Vendor Name:** Datexel S.r.l.  
**Vendor ID:** 0x078B  
**Device Name:** DAT11188PN  
**Device ID:** 0x000B  
**Product family:** Datexel DAT11000 series  
**Main Family:** I/O

**Protocol implemented:** PROFINET IO  
**PN\_IO version:** v 2.44  
**Requires Engineering Tool which supports at least GSDML version:** v 2.25

**Supported RT Classes:** RT CLASS 1  
**Conformance Class:** B  
**Netload Class :** III

**Address assignment:** Profinet DCP

**I&M records supported:** 1,2,3,5

**Additional protocols supported:** SNMP, LLDP, MRP (as Client)  
**Web Server supported:** yes on Port 80 with HTTP protocol

**Ethernet ports number:** 2  
**Mautype:** 16 (100BaseTXFD)

**Number of slots:** 3  
**Slot IDs:** 0 (DAP) ,1 (Input Objects), 2 (Output Objects)

**Cyclic data:**  
**Number of Input bytes:** 32  
**Number of Output bytes:** 4

**Parameters**  
**Number of bytes:** 6

**Factory default state**  
**Station Name:** "" (empty string – not name assigned)  
**IP Address:** 0.0.0.0  
**Subnet Mask:** 0.0.0.0  
**Gateway Mask:** 0.0.0.0

### INPUT / OUTPUT DATA OBJECT STRUCTURE

The Input / Output objects are represented in **Unsigned Integer 16 bit** format.

For Unsigned Integer 16 bit format, the values are composed of 2 bytes ordered as represented in the Structure 1 below.

The range of value is between 0 and 65535.

If the value of a data is used to represent a number for which it is foreseen the sign (i.e. analogue input measure) it is necessary subtract 65536 from the read value to obtain the true signed value. Refer to the description of the single object to know the number of decimal digits.

**Structure 1:** Unsigned Integer 16 bit structure :

Bit	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Descr	MSB	-	-	-	-	-	-	-	-	-	-	-	-	-	-	LSB
Byte	HB (1 byte)								LB (1 byte)							

Meaning:

MSB → Most Significant Bit


LSB → Least Significant Bit

HB → High Byte

LB → Low Byte

## DEVICE LEDs FUNCTION

### Front LEDs layout




### List of LEDs

LED name	LED state	Condition	Description
PWR	Off	Device not powered	- No Power supply voltage applied to the device
	Green	Device powered	- Power supply voltage applied to the device
	Green, blinking	Device in Watchdog	- Refer to Watchdog chapter
STS	Off	Outputs correctly working	- Correct working
	Yellow, blinking	Short circuit alarm active	- Short circuit on output detected
NS	Off	Offline	- With PWR Off : device not power - With PWR Green: no connection with IOC
	Green	Online (RUN)	- Connection with IOC established - IO Controller in RUN state
	Green, 1 flash	Online (STOP)	- Connection with IOC established - IOC in STOP or IO data bad
	Green, blinking	Blink	Used by engineering tool to identify the node on the network
	Red	Fatal event	Major internal error (combined with MS led red)
	Red, 1 flash	Station Name error	Station Name not set
	Red, 2 flashes	IP address error	IP address not set
MS	Red, 3 flashes	Configuration error	- IP address conflict - Expected Identification differs from Real Identification
	Off	Not Initialized	- With PWR Off : device not power - With PWR Green : module is initializing
	Green	Normal operation	Correct working
	Green, 1 flash	Diagnostic Event	Diagnostic event present
I0	Red	Fatal event	Major internal error (combined with NS led red)
	Exception error	Device in exception	
I0	Off	Digital Input 0 OFF	State of Digital Input 0
	Red	Digital Input 0 ON	
I1	Off	Digital Input 1 OFF	State of Digital Input 1
	Red	Digital Input 1 ON	
I2	Off	Digital Input 2 OFF	State of Digital Input 2
	Red	Digital Input 2 ON	
I3	Off	Digital Input 3 OFF	State of Digital Input 3
	Red	Digital Input 3 ON	
I4	Off	Digital Input 4 OFF	State of Digital Input 4
	Red	Digital Input 4 ON	
I5	Off	Digital Input 5 OFF	State of Digital Input 5
	Red	Digital Input 5 ON	
I6	Off	Digital Input 6 OFF	State of Digital Input 6
	Red	Digital Input 6 ON	
I7	Off	Digital Input 7 OFF	State of Digital Input 7
	Red	Digital Input 7 ON	

LED name	LED state	Condition	Description
O0	Off	Digital Output 0 OFF	State of Digital Output 0
	Red	Digital Output 0 ON	
O1	Off	Digital Output 1 OFF	State of Digital Output 1
	Red	Digital Output 1 ON	
O2	Off	Digital Output 2 OFF	State of Digital Output 2
	Red	Digital Output 2 ON	
O3	Off	Digital Output 3 OFF	State of Digital Output 3
	Red	Digital Output 3 ON	
O4	Off	Digital Output 4 OFF	State of Digital Output 4
	Red	Digital Output 4 ON	
O5	Off	Digital Output 5 OFF	State of Digital Output 5
	Red	Digital Output 5 ON	
O6	Off	Digital Output 6 OFF	State of Digital Output 6
	Red	Digital Output 6 ON	
O7	Off	Digital Output 7 OFF	State of Digital Output 7
	Red	Digital Output 7 ON	

### DEVICE LEDs FUNCTION

#### Ethernet LEDs layout



#### List of LEDs

LED name	LED state	Condition	Description
LED1	Off	Default	Not used; always in default state
LED2	Off	Link not sensed on Port 1	- Ethernet not connected - Ethernet MAU Type different from 100 Mbps Full duplex
	Green , blinking	Link / Act sensed on Port 1	Correct working
LED3	Off	Default	Not used; always in default state
LED4	Off	Link not sensed on Port 2	- Ethernet not connected - Ethernet MAU Type different from 100 Mbps Full duplex
	Green / Blinking	Link / Act sensed on Port 2	Correct working

## NETWORK PARAMETERS ASSIGNMENT

The network parameters such as the Station Name, the IP Address, the Subnet Mask and the Gateway Mask are set using the Discovery and Basic Configuration Protocol (DCP), that is the protocol for PROFINET used for name and address resolution.

The data can be saved Temporarily or Permanently.

If the data are saved Temporarily they will be lost when the device is powered off.

If the data are saved Permanently they will be kept when the device is powered off.

All of the data are set to factory default if a command of Reset takes place. For the description see the next chapter.

## RESET TYPES SUPPORTED

A factory reset command from the network is done using the Discovery and Basic Configuration Protocol (DCP). The device supports the reset modes 2 and 8 described below.

Behavior of the device:

### • Reset To Factory mode 2

IP Address = "0.0.0.0"

Subnet Mask = "0.0.0.0"

Gateway Address = "0.0.0.0"

DNS1 = "0.0.0.0"

DNS2 = "0.0.0.0"

Host name = NULL

Domain name = NULL

Station Name = ""

– SNMP MIB-II variables:

• sysName = empty string

• sysContact = empty string

• sysLocation = empty string

– All PDev parameters set to default values.

### • Reset To Factory mode 8 and (legacy) FactoryReset

IP Address = "0.0.0.0"

Subnet Mask = "0.0.0.0"

Gateway Address = "0.0.0.0"

DNS1 = "0.0.0.0"

DNS2 = "0.0.0.0"

Host name = NULL

Domain name = NULL

Station Name = ""

– SNMP MIB-II variables:

• sysName = empty string

• sysContact = empty string

• sysLocation = empty string

– All PDev parameters set to default values.

– I&M1-3 set to default values.

## PARAMETERS MAPPING

Byte Position	Description	Register Type/Format	Access
0 - 1	Bit 0 to 7 - Powerup value / Bit 8 to 15 Safe value	16-bit, Unsigned	WO
2 - 3	Debouncing Time as ms	16-bit, Unsigned	WO
4 - 5	Watchdog Time as sec	16-bit, Unsigned	WO

## CYCLIC INPUT DATA MAPPING

Byte Position	Description	Register Type/Format	Access
0 - 1	System Flags	16-bit, Unsigned	RO
2 - 3	Digital Outputs readback	16-bit, Unsigned	RO
4 - 5	Digital Inputs	16-bit, Unsigned	RO
6 - 7	Digital Input Rise Latch	16-bit, Unsigned	RO
8 - 9	Digital Input Fall Latch	16-bit, Unsigned	RO
10 - 11	Low part 32 bit Counter 0	16-bit, Unsigned	RO
12 - 13	High part 32 bit Counter 0	16-bit, Unsigned	RO
14 - 15	Low part 32 bit Counter 1	16-bit, Unsigned	RO
16 - 17	High part 32 bit Counter 1	16-bit, Unsigned	RO
18 - 19	Low part 32 bit Counter 2	16-bit, Unsigned	RO
20 - 21	High part 32 bit Counter 2	16-bit, Unsigned	RO
22 - 23	Low part 32 bit Counter 3	16-bit, Unsigned	RO
24 - 25	High part 32 bit Counter 3	16-bit, Unsigned	RO
26 - 27	Power up / Safe readback	16-bit, Unsigned	RO
28 - 29	Debouncing Time readback	16-bit, Unsigned	RO
30 - 31	Watchdog Timeout readback	16-bit, Unsigned	RO

## CYCLIC OUTPUT DATA MAPPING

Byte Position	Description	Register Type/Format	Access
0 - 1	Digital Outputs	16-bit, Unsigned	WO
2 - 3	Reset/Enable flags	16-bit, Unsigned	WO

WO = Write Only  
RO = Read Only

## PARAMETERS

Definitions:

IOC = Controller IO;

AR = Application Relation: connection established between one or more IOC and the slave devices during the startup of a communication process.

It is possible to set the following parameters each time the IOC establishes an AR. Each parameter can be read back in the cyclic input data in order to check, if desired, the value of the parameters.

Parameter's bytes 0(L)/1(H) "Bit 0 to 7 - Powerup value / Bit 8 to 15 Safe value" – Values allowed from 0 up to 65535

Parameter's bytes 2(L)/3(H) : "Debouncing Time as ms" – Values allowed from 1 up to 255

Parameter's bytes 4(L)/5(H) : "Watchdog Time as sec" – Values allowed from 0 up to 255

### PARAMETERS: POWER-UP / SAFE / WATCHDOG

The Power-Up (Bit 0÷7) condition sets the outputs of the device to a predefined value each time the device is powered-up.

The Safe (Bit 0÷15) condition sets the outputs of the device to a predefined value if the IOC has established an AR with the device performing a cyclic communication and the link state of the Ethernet is not sensed **on both** the ports for the time specified in the Parameter "Watchdog Time as sec" or if the IOC release the AR ,goes in debug and the link state of the Ethernet is not sensed **on both** the ports for the time specified in the Parameter "Watchdog Time as sec".

The value of the Power-up and Safe can be read cyclically in bytes 26/27 "Power up / Safe read back" of the Input Cyclic Data.

The value of the Power-up and Safe can be set in the Parameter "Bit 0 to 7 - Powerup value / Bit 8 to 15 Safe value". See table below for the association of bits to the digital outputs.

The Watchdog timer is disabled and doesn't work if the Parameter "Watchdog Time as sec" is set to 0 (default)

The Watchdog timer works if the Parameter "Watchdog Time as sec" is different from 0. The parameter is written each time the IOC establishes an AR with the device and it is expressed as seconds. The Watchdog bit will be set to 1 (see the description of "System Flags").

The value of the Watchdog time can be read cyclically in bytes 30/31 "Watchdog Timeout Read Back" of the Input Cyclic Data.

Bit	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Out #	Out 7	Out 6	Out 5	Out 4	Out 3	Out 2	Out 1	Out 0	Out 7	Out 6	Out 5	Out 4	Out 3	Out 2	Out 1	Out 0
Descr	Safe								Power-Up							

### PARAMETERS: DEBOUNCING TIME (MINIMUM DURATION PULSE)

The *Minimum Acceptable Pulse Duration* is set in this parameter so that the change of state or the counting of the counters is detected.

This function is applied to all of the digital inputs.

By setting this parameter, all pulses or spikes with a duration shorter than this value are *"filtered"/ ignored*. This allows, for example, to filter the spikes during the opening or closing of a mechanical contact (flow meters, litre counters, etc.) and therefore to get a *"clean"* counting in the pulse counter.

The value is expressed as milliseconds (ms).

The values must be between 1 and 254 ms.

The value 255 forces the minimum pulse duration to 50 ms.

The value of the Debouncing time can be read cyclically in bytes 28/29 "Debouncing Time readback" of the Input Cyclic Data.

EXAMPLE:

If the value written is 10, all pulses with duration shorter than 10 ms are filtered / ignored.

## CYCLIC INPUT DATA MAPPING

### SLOT ASSIGNMENT: USED IN SLOT 1 , FIXED IN SUB-SLOT 1

#### BYTES 0 – 1: SYSTEM FLAGS

This object allows to retrieve the system events of the device. The following parameters are implemented.

**Supervising Bits (bits 0,1,2):** the combination of the values given by these 3 bits indicates the status of the device.

Bit 0 = 0; Bit 1 = 1; Bit 2 = 0; status "WAIT PROCESS": the device is waiting for being supervised by an IOC

Bit 0 = 1; Bit 1 = 1; Bit 2 = 0; status "IDLE" :the device has been supervised by an IOC but now the IOC is in STOP

Bit 0 = 0; Bit 1 = 0; Bit 2 = 1; status "PROCESS ACTIVE" :the device is supervised by an IOC

Bit 0 = 1; Bit 1 = 0; Bit 2 = 1; status "ERROR" :the device has detected an error condition

Bit 0 = 1; Bit 1 = 1; Bit 2 = 1; status "EXCEPTION" :the device is in exception state

**Watchdog Event Enable (bit 8):** this bit shows if the Watchdog event is disabled (0) or enabled (1). If enabled and the IOC has established an AR with the device performing a cyclic communication and the link state of the Ethernet is not sensed **on both** the ports for the time specified in the Parameter "Watchdog Time as sec" or if the IOC has released an AR and is in debug state and the link state of the Ethernet is not sensed **on both** the ports for the time specified in the Parameter "Watchdog Time as sec", the PWR led flashes and the status of the outputs is automatically set as defined in the high byte of the "Bit 0 to 7 - Powerup value / Bit 8 to 15 Safe value" parameter. The "Watchdog Event Enable" bit resides in Eeprom therefore, in case of power failure, it maintains its status.

**Watchdog Event (bit 9):** if this bit is set to 1 indicates that the Watchdog condition has occurred (0 = Normal condition; 1 = alarm condition)

When the Watchdog event has occurred, this bit can be reset setting to 1 the bit 9 of the object "Reset/Enable Flags" of the Cyclic Output Data

**Power-Up Event (bit 10):** this bit is forced to 1 at each power on and indicates that the device has been switched off. With the setting of this bit to 0 and checking its state, it is possible to monitor if an unexpected power-off of the device has occurred (0 = power-off not occurred; 1 = power-off occurred).

This bit can be reset setting to 1 the bit 10 of the object "Reset/Enable Flags" of the Cyclic Output Data .

**Short circuit Event (bit 12):** the device is equipped with a sensor to detected short-circuits (protection against the over-currents) on digital outputs. In case of short-circuit on output, this bit is forced to 1. If this alarm is active the device must be reset and the connections checked (0 = over-currents protection not activated ; 1 = over-currents protection activated).

This bit can be reset setting to 1 the bit 12 of the object "Reset/Enable Flags" of the Cyclic Output Data .

Bit	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Descr	<div style="display: flex; justify-content: space-between; align-items: center;"> <div style="text-align: left;"> <p>Short circuit Event</p> <p>Power-up Event</p> <p>Watchdog Event</p> <p>Watchdog Event Enable</p> </div> <div style="text-align: right;"> <p>Supervising Bits</p> </div> </div>															

#### BYTES 2 – 3: DIGITAL OUTPUTS READ BACK

This object allows to monitor the state of the output relays driven in the object "Digital Outputs" of the Cyclic Output Data (0 = OFF ; 1 = ON).

Bit	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Out #	-	-	-	-	-	-	-	-	Out 7	Out 6	Out 5	Out 4	Out 3	Out 2	Out 1	Out 0

#### BYTES 4 – 5: DIGITAL INPUTS

This object shows the condition of the digital inputs (0 = OFF; 1 = ON).

Bit	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
In #	-	-	-	-	-	-	-	-	In 7	In 6	In 5	In 4	In 3	In 2	In 1	In 0

#### BYTES 6 – 7: DIGITAL INPUTS RISE LATCH

The bits of this object are used to indicate that an event of change of logic state of digital input from 0 to 1 (rise latch) has occurred . The latch event shows for each digital input the single change of state and is not updated by the system. It is possible to reset the whole object setting to 1 the bit 4 of "Reset/Enable Flags" of the Cyclic Output Data .

Bit	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Latch	-	-	-	-	-	-	-	-	In 7	In 6	In 5	In 4	In 3	In 2	In 1	In 0

#### BYTES 8 – 9: DIGITAL INPUTS FALL LATCH

The bits of this object are used to indicate that an event of change of logic state of digital input from 1 to 0 (fall latch) has occurred . The latch event shows for each digital input the single change of state and is not updated by the system. It is possible to reset the whole object setting to 1 the bit 5 of "Reset/Enable Flags" of the Cyclic Output Data .

Bit	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Latch	-	-	-	-	-	-	-	-	In 7	In 6	In 5	In 4	In 3	In 2	In 1	In 0

### **BYTES 10 – 11 (LOW) / BYTES 12 – 13: 32 BIT COUNTER DIGITAL INPUT 0**

These four bytes contains the measure of the digital counter related to the input channel 0. The value is incremented at each change of state from 0 to 1 of the input channel 0. The type of data created is an *Unsigned Long 32 bit*.

It is possible to reset the value of the counter setting to 1 the bit 0 of the object "Reset/Enable Flags" of the Cyclic Output Data.

**Note:** The counter is **not** retentive. When the device is switched off, the value contained in these bytes is lost.

### **BYTES 14 – 15 (LOW) / BYTES 16 – 17: 32 BIT COUNTER DIGITAL INPUT 1**

These four bytes contains the measure of the digital counter related to the input channel 1. The value is incremented at each change of state from 0 to 1 of the input channel 1. The type of data created is an *Unsigned Long 32 bit*.

It is possible to reset the value of the counter setting to 1 the bit 1 of the object "Reset/Enable Flags" of the Cyclic Output Data.

**Note:** The counter is **not** retentive. When the device is switched off, the value contained in these bytes is lost.

### **BYTES 18 – 19 (LOW) / BYTES 20 – 21: 32 BIT COUNTER DIGITAL INPUT 2**

These four bytes contains the measure of the digital counter related to the input channel 2. The value is incremented at each change of state from 0 to 1 of the input channel 2. The type of data created is an *Unsigned Long 32 bit*.

It is possible to reset the value of the counter setting to 1 the bit 2 of the object "Reset/Enable Flags" of the Cyclic Output Data.

**Note:** The counter is **not** retentive. When the device is switched off, the value contained in these bytes is lost.

### **BYTES 22 – 23 (LOW) / BYTES 24 – 25: 32 BIT COUNTER DIGITAL INPUT 3**

These four bytes contains the measure of the digital counter related to the input channel 3. The value is incremented at each change of state from 0 to 1 of the input channel 3. The type of data created is an *Unsigned Long 32 bit*.

It is possible to reset the value of the counter setting to 1 the bit 3 of the object "Reset/Enable Flags" of the Cyclic Output Data.

**Note:** The counter is **not** retentive. When the device is switched off, the value contained in these bytes is lost.

### **BYTES 26 – 27: POWER-UP / SAFE READ BACK**

This object allows to read the value set in Parameter "Bit 0 to 7 - Power-Up value / Bit 8 to 15 Safe value" (0 = bit not enabled; 1 = bit enabled).

Bit	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Out #	Out 7	Out 6	Out 5	Out 4	Out 3	Out 2	Out 1	Out 0	Out 7	Out 6	Out 5	Out 4	Out 3	Out 2	Out 1	Out 0
Descr	Safe								Power-Up							

### **BYTES 28 – 29: DEBOUNCING TIME READ BACK**

This object allows to read the value set in Parameter "Digital Input Debouncing Time as milliseconds"

### **BYTES 30 – 31: WATCHDOG TIMEOUT READ BACK**

This object allows to read the value set in Parameter ""Watchdog Time as sec""

## CYCLIC OUTPUT DATA MAPPING

**SLOT ASSIGNMENT: USED IN SLOT 2 , FIXED IN SUB-SLOT 1**

### BYTES 0 – 1: DIGITAL OUTPUTS

This object allows to drive the state of the output relays (0 = OFF ; 1 = ON).

The value of this object can be read cyclically in bytes 2/3 "Digital Outputs Read Back" of the Input Cyclic Data

Bit	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Out #	-	-	-	-	-	-	-	-	Out 7	Out 6	Out 5	Out 4	Out 3	Out 2	Out 1	Out 0

### BYTES 2 – 3: RESET / ENABLE FLAGS

The set to 1 of the bits of this object allow to do the following system operations:

- **Reset counter digital input 0 (Bit 0):** the value of 32 bit Counter Digital Input 0 (Cyclic Input bytes 10 - 11 - 12 - 13) will be set to 0
- **Reset counter digital input 1 (Bit 1):** the value of 32 bit Counter Digital Input 1 (Cyclic Input bytes 14 - 15 - 16 - 17) will be set to 0
- **Reset counter digital input 2 (Bit 2):** the value of 32 bit Counter Digital Input 2 (Cyclic Input bytes 18 - 19 - 20 - 21) will be set to 0
- **Reset counter digital input 3 (Bit 3):** the value of 32 bit Counter Digital Input 3 (Cyclic Input bytes 22 - 23 - 24 - 25) will be set to 0
- **Reset Rise Latch object (Bit 4):** the value of Digital Input Rise Latch (Cyclic Input bytes 6 - 7) will be set to 0
- **Reset Fall Latch object (Bit 5):** the value of Digital Input Fall Latch (Cyclic Input bytes 8 - 9) will be set to 0
- **Reset Watchdog event bit (Bit 9):** the value of Watchdog Event in System Flags (bit 9 Cyclic Input bytes 0 - 1) will be set to 0
- **Reset Power-Up bit (Bit 10):** the value of Power-Up Event in System Flags (bit 10 Cyclic Input bytes 0 - 1) will be set to 0
- **Reset Short circuit alarm bit (Bit 12):** the value of Short circuit alarm Event in System Flags (bit 12 Cyclic Input bytes 0 - 1) will be set to 0


Bit	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Descr																

## IMPORTING THE DEVICE IN TIA PORTAL


The following example has the purpose to show how to insert the GSDML file of the device in SIEMENS TIA PORTAL. It has been done using SIEMENS TIA PORTAL V17 and a PLC S7-1200; the example includes the creation of a new project using ladder. Run TIA PORTAL and wait for the application to be executed.

### **Step 1: create a new project.**

Click Start (A) → Create New Project (A1) → Set the name and path of the project (A2) → Click Create (A3)




Wait for the creation of the project.  
Click "Configure a device" (A4)




### **Step 2: Add the PLC.**


Be sure that the PLC has been powered on and connected to the network. Click Add new device (A5) → Click Controllers (A6) → Select the Controller from the menus (A7)



When the Controller has been selected click "Add" (A8)




Follow the wizard to define the security settings editing them as required from the project. When the procedure is completed click "Finish" (A9)



The PLC is added to the project.

### Step 3: Set PLC Network.

In the project tree click the branch of PLC (B) and after double click on “Device configuration” (B1)  
Double click on PLC in the Device view of the project (B2).



The properties section appears below the project window.


Click the frame “General” (B3)

Click the branch “PROFINET Interface [X1]” (B4)

Click the branch “Ethernet addresses” (B5)

Scroll the scroll bar on the right down until you reach the section “Internet protocol version 4 (IPv4)” (B6)


Set the value of the IP address (B7) and press Enter. In this example the IP address of PLC is set to 192.168.1.88



### Step 4: Import the GSD file of the device in the project


Download the GSDML file of the device from the website [www.datexel.it](http://www.datexel.it) to a folder in your PC.

On the menu bar click “Options” → “Manage general station description file (GSD)” (C)




The window that allow to import the GSDML file will be opened (next page)

Click the button “...” (C1)  
Select the path where the GSDML file has been downloaded




In the folder selected there may be more than one GSDML file; in this case all of the files corresponding to GSDML extension in the folder will be listed. Select the file about the device from the list (C2)  
Click “Install” (C3)



The system will take some time to complete the installation of the GSDML file and add it to the “Hardware catalog”.


**Step 5: Add the device to the project**

In the Project tree double click on the branch “Devices and networks” (D).



On the right of the software window some side menus will appear.


- Click on "Hardware catalog" (D1)
- Click "Other field devices" (D2)
- Click "PROFINET IO" (D3)
- Click "I/O" (D4)
- Click "Datexel S.r.l." (D5)
- Click "Datexel DAT11000 series" (D6)
- Click "dat11188pn" (D7) and drag and drop it to the project.




The device will be added to the project.

**Step 6: Link the device to PLC and configure it.**


In "Devices and networks" → "Network view" right click of the mouse on the device's symbol, label "Not assigned" (E).  
Click "Assign to new IO controller" (E1)



A window that let to select the controller will appear (next page)



Select the controller (E2).  
Click OK (E3). The device will be linked to PLC and its network.



Double click on the device (E4), click the image of the device it appears (E4A).  
The properties section appears below the project window.

Click the frame "General" (E5)


Click the branch "PROFINET Interface [X1]" (E6)

Click the branch "Ethernet addresses" (E7)


Scroll the scroll bar on the right down until you reach the section "Internet protocol version 4 (IPv4)" (E8)

Set the value of the IP address (E9) and press Enter. In this example the IP address of the device is set to 192.168.1.18

Doing this, the IP parameter will be assigned in the project.



To establish a connection in PROFINET it is mandatory to assign a specific Station Name to the device otherwise it will result in a communication error. Scroll the scroll bar on the right down until you reach the section "PROFINET" (E10).



If the flag "Generate PROFINET device name automatically" (E11) is checked, the default Station Name in GSDML file will be assigned. In PROFINET there can't be different devices with the same Stations name. If the flag is unchecked, it is possible to assign the name manually (E12). When PROFINET device name is modified the software will update automatically the field "Converted Name".

After the name has been set, it is necessary to assign the name to the device.

Look for the devices connected.


In the tool bar click the icon for Accessible devices (E13)




Before to proceed be sure that the device has been powered on and connected to the network.

Select the interface (E14) and network (E15)


Click Start search (E16)




When the search for the devices connected is over, the devices will be listed and our device is included in it (E17)




Click "Cancel", go back to "Device overview", double click on the device dat11188pn and click on button "Assign device name" (E18)




Click "Update list" (E19)



When the list is filled, click on the row of the device (E20); click "Assign name" (E21)



When the name is assigned, the status OK appears on the row of the device (E22)



### Step 7: Creation of variables and mapping to the objects.


This example is about how to map the "Digital Inputs" and "Digital Outputs" variables.

Note: for the position of the variables you want to map always refer to the previous chapters of this document.

Select the device in "Devices and Network".


On the top right corner select "Device view" (F)

Select the row of Input Objects (F1)




The "Digital Inputs" are mapped to the bytes 4 and 5 of the Cyclic Input Data (third position in the array).

In the properties of Input Objects, frame IO tags (F2) in the column "Name" write the name of the variable that you want to be mapped in the third position of the array (F3); in the column "Tag table" select "Default tag table" (F4).




In "Device view" (F), select the row of Output Objects (F5)




The "Digital Outputs" are mapped to the bytes 0 and 1 of the Cyclic Output Data (first position).

In the properties of Output Objects, frame IO tags (F6) in the column "Name" write the name of the variable that you want to be mapped in the third position of the array (F7); in the column "Tag table" select "Default tag table" (F8).



In the Project tree select the PLC, select PLC tags (F9), double click on Default tag table (F10).




It will show the variables mapped (next page).

Default tag table								
	Name	Data type	Address	Retain	Acces...	Writa...	Visibl...	Comment
1	Digital Inputs	Int	%IW72	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
2	Digital Outputs	Int	%QW64	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
3	<Add new>			<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	


**Step 8: Creation of the project.**

In this example it will be show a very simple project composed of a “Move” function with the purpose of moving the value on the inputs of the device to the outputs. Moreover, this example has also the purpose of show how to set the module parameters.


In the Project tree under the branch of PLC select “Program blocks” (G), right click on it and select “Add new block” (G1)




Select “Program cycle” (G2) from “Organization block” (G3) and click OK (G4).



It will be created an empty project.




In the Project tree, double click on the block “Main” (G5).




On the right it will appear the menu “Instructions”.


Click "Basic Instructions"(G6) → "Move operations" (G7) → "MOVE" (G8)




The instruction will be added to the project.



Click '<???' IN to define the input variable (G9)  
Select the variable (G10). In this example the variable is "Digital Inputs"




Click '<???' OUT to define the output variable (G11)  
Select the variable (G12). In this example the variable is "Digital Outputs"




The Move instruction needs an enable bit. It can be set using any available boolean. In this example a User constant defined in the "Default tag table" is used.

Default tag table				
	Name	Data type	Value	Comment
1	En_bit	Bool	TRUE	
2	<Add new>			

Insert an open contact in the “EN” branch and click on <??.> to assign the variable (G13).




The simple project is complete.




**Step 9: Set the module parameters**

The parameters allow the setting of the system functions for the device when the PLC establishes the connection with it. All of these parameters can be monitored by means of Read back objects in Cyclic Input Data. To set the parameters go to “Network view”, select the dat1188pn, go to “Device view”, double click on the device image. In properties under frame “General” click “Module parameters” (H). Set the values as desired between the limits shown (H1) and press Enter.



**Step 10: Compile the project, download it to PLC and monitor the variables**

In the Project tree select the branch of PLC. In the Toolbar click “Compile” (I). When the project is compiled, in the Toolbar click Download to device (I1) and follow the procedure to end the download correctly. When the download is complete, in the Toolbar click “Start CPU” (I2) and when asked by the system go in RUN mode. In the Toolbar click “Go online” (I3). If there are not errors all the fields related with PLC communication are marked in green.



To monitor the variables go to PLC tag → Default tag table. Click “Monitor all” (I4)

	Name	Data type	Address	Retain	Acces...	Writa...	Visibl...	Monitor value	Comment
1	Digital Inputs	Int	%IW72		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	
2	Digital Outputs	Int	%QW64		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	
3	<Add new>				<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		


In the column “Monitor value” (I5) is it possible to see the variables changing.

## IMPORTING THE DEVICE IN CODESYS

The following example has the purpose to show how to insert the GSDML file of the device and it has been done using CODESYS 3.5 SP19 Patch 6 Soft PLC that includes the creation of a new project using a standard project template with PLC\_PRG in standard text. Run Codesys and wait for the application to be executed.

### Step 1: create a new project.

Click File → New Project.




Select icon "Standard project" (A).


Edit the name of the project (A1).

Click OK (A2).

Edit the project as follows and click OK (A3).




The following screen with the basic project functions will appear.



## Step 2: Connect to PLC


This step may change in function of the PLC used. Activate the PLC.

Double click on "Device" in the tree-view of the project, click Communication Settings (B), insert the credential to access the PLC if required and click Scan Network (B1). Select the PLC and connect to it to obtain the following window with green marks.




## Step 3: insert an Ethernet Interface.


In the tree-view of the project select and right click of the mouse on "Device (Codesys Control Win V3)" (C) .




Select Add Device; the following window will appear.



Select "Fieldbuses" (D) → select "Ethernet Adapter" (D1) → Select "Ethernet" (D2). Click button "Add Device" (D3). The branch Interface "Ethernet" will be added to the tree-view of the project (D4)




Double click on "Ethernet" (D4). The following window appears. Click button "Browse" (D5). Select the network interface and click button "OK" (D6).




#### Step 4: Insert PN Controller.

In the tree-view of the project select and right click of the mouse on “Ethernet” (E)




Select “Add Device”; the following window will appear



Select “Fieldbuses” (E1) → select “PROFINET IO” (E2) → Select “PROFINET IO Master” (E3) → “Select PN Controller” (E4). Click button “Add Device” (E5).

The element “PN Controller” will be added under the branch “Ethernet” to the tree-view of the project (E6)



Set the Station name of Controller (E7)


Compatibly with the IP address of Ethernet that has been set in step 3:

set the First IP Address (E8)

set the Last IP address (E9)

set the Subnet Mask (E10)

set the Gateway Mask (E11)




**Step 5: Install the GSDML file of the device into Device Repository of Codesys.**

Download the GSDML file of the device from the website [www.datexel.it](http://www.datexel.it) to a folder in your PC.


In the Menu bar of Codesys click “Tools” → “Device Repository...”

The following window appears.




Select “Fieldbuses” (F) → select “PROFINET IO” (F1) → Select “PROFINET IO Slave” (F2) → Click button “Install” (F3).

The window “Install Device Description” will appear; recall the path of the folder wherein you downloaded the GSDML file of the device, select it and click “Open” (F4) (next page).




The file will be installed under the folder “I/O” (Main family of the device). If it is the first time that a Datexel’s device is installed, Codesys will create the folder “Datexel DAT11000” (F5), otherwise the device’s GSDML will be added inside it. Select the file installed (F6) and click “Close” (see previous page - F7) on Device Repository window.




**Step 6: Scan the network for the device and add it to the project.**



In the Menu bar of Codesys click “Build”→ “Clean” and after click “Build”→ “Generate Code”. Once the project has been compiled in the Menu bar of Codesys click “Online”→ “Login” to login to the PLC. In the tree-view of the project right click of the mouse on the element “PN Controller”. Check that the device has been powered-on and that the Ethernet cable is connected to Port1 or Port2. Select “Scan for Devices”. The below window will appear, the system takes some seconds and the device will be listed.



Being provided as Factory default the device is supplied with communication parameters not set. To import the device in the project it is necessary set them as follows. Select the row of the device (G) Edit the Station Name in the proper column (G1); example: “dat1188pn” Edit the Network Parameters in the proper columns (G2); example: IP Address:”192.168.1.18” Subnet Mask: “255.255.255.0” Gateway Mask:”192.168.1.1” Click “Set Name and IP” (G3) and wait for the end of operation. Click “Scan Devices” (G4). The below window will appear and after some seconds the device will be listed and updated.



To import the device in the project select the row of the device (G5) and click “Copy to project” (G6). The device will be added to the tree-view of the project as a branch of the element “PN Controller”. In the Menu bar of Codesys click “Online”→ “Logout”.



Double click on the line of the DAP icon of the device (H3).

In the window that will appear it is possible to set the parameters of the device that are not included in the cyclic Process Data Objects. These parameters will be set each the PLC establishes an AR. See next page.

Click "General" (H6)

Parameters	Value	Data Type	Allowed Values	Description
Bit 0 to 7 - Powerup value / Bit 8 to 15 Safe value	0	Unsigned16	0..65535	
Debouncing Time as ms	1	Unsigned16	1..255	
Watchdog Time as sec	10	Unsigned16	0..255	

Edit the desired values of the parameters writing them within limits in the column "Value" of each row (H7).  
 To map the "Digital Inputs" object double click on the line dat11188pn\_1 (Input Objects) - (H4) in the tree-view of the project.  
 Click "PNIO Module I/O Mapping" (H8). Double click on the line of the object to map, in this example "Digital Inputs" (H9).  
 The window Input Assistant appears. Click on the variable to be mapped (H10).  
 Click "OK" (H11). The object will be associated to the variable

Variable	Mapping	Channel	Address	Type	Unit	Description
Inputs		%IW2		UINT		
System Flags		%IW2		UINT		
Digital Outputs ReadBack		%IW3		UINT		
Digital Inputs		%IW4		UINT		
Digital Inputs Rise Latch		%IW5		UINT		
Digital Inputs Fall Latch		%IW6		UINT		
Low part 32 bit Counter 0		%IW7		UINT		
High part 32 bit Counter 0		%IW8		UINT		
Low part 32 bit Counter 1		%IW9		UINT		
High part 32 bit Counter 1		%IW10		UINT		
Low part 32 bit Counter 2		%IW11		UINT		
High part 32 bit Counter 2		%IW12		UINT		
Low part 32 bit Counter 3		%IW13		UINT		
High part 32 bit Counter 3		%IW14		UINT		
Power Up / Safe ReadBack		%IW15		UINT		
Debouncing Time ReadBack		%IW16		UINT		
Watchdog Timeout ReadBack		%IW17		UINT		
Inputs PS		%IB36		Enumerated		

Name	Type	Address	Origin
In0	UINT		
Out	UINT		
IoConfig_Glob...	VAR_GLOBAL		
IoDrvEthernet	Library		IoDrvEthernet, 4.2...

Input mapped.

Variable	Mapping	Channel	Address	Type
		Inputs	%IW2	
		System Flags	%IW2	UINT
		Digital Outputs ReadBack	%IW3	UINT
Application.PLC_PRG.In0		Digital Inputs	%IW4	UINT
		Digital Inputs Rise Latch	%IW5	UINT
		Digital Inputs Fall Latch	%IW6	UINT

To map the output object double click on the line dat11188pn\_2 (Output Objects) - (H5) in the tree-view of the project. Click "PNIO Module I/O Mapping" (H12). Double click on the line of the object to map, in this example "Digital Outputs" (H13). The window Input Assistant appears. Click on the variable to be mapped (H14). Click "OK" (H15). The object will be associated to the variable

The screenshot shows the 'PNIO Module I/O Mapping' window with a table of I/O channels. The 'Digital Outputs' row is selected. The 'Input Assistant' dialog is open, showing a tree view of variables where 'Out' is selected. The 'OK' button is highlighted with a red arrow.

Variable	Mapping	Channel	Address	Type	Unit	Description
		Outputs	%QW0			
		Digital Outputs	%QW0	UINT		
		Reset / Enable Flags	%QW1	UINT		
		Outputs CS	%B37			


Name	Type	Address	Origin
Application	Application		
PLC_PRG	PROGRAM		
In0	UINT		
Out	UINT		
DED	Library		CAA Device Diagnosi...
ToConfig_Glob...	VAR_GLOBAL		
ToDrvEthernet	Library		IoDrvEthernet, 4.2...

Output mapped.


Variable	Mapping	Channel	Address	Type	Unit	Description
		Outputs	%QW0			
Application.PLC_PRG.Out		Digital Outputs	%QW0	UINT		
		Reset / Enable Flags	%QW1	UINT		
		Outputs CS	%B37	Enumeration of BYTE		

### Step 8: run the project.

After the mapping of variables is complete, it is necessary to define the communication cycle time. In the tree-view of the project double click on the element "Profinet Communication Task" (I) Define the interval of execution as milliseconds (I1)



in the Menu bar of Codesys click "Build"→"Clean" and after click "Build"→"Generate Code". When the project has been compiled in the Menu bar of Codesys click "Online"→"Login" to login to the PLC. Click "Debug"→"Start". If the communication ends correctly the project tree looks like as follows with all green marks.



Clicking on PLC\_PRG, it will be possible to see the variables changing.



## WEB-SERVER

The device is supplied by default with the IP address set to 0.0.0.0. Therefore it is not possible to access the web-server with an “out of the box” device. It is necessary to assign to the device a valid IP address.

To do it, before to run the web browser:


- assign via PROFINET DCP a valid IP address and Subnet Mask
- tip in the address bar of the web browser the device's IP address. It will appear the Home page

**For the devices using PROFINET the web server is intended for visualization only.**

Due to this there won't be required any credentials to access it.


Depending on the Web browser in use some icons and/or graphics may appear with little variation in shape and colour. The supported web browsers are: *Chrome, Firefox, Opera and Edge.*

### Home page



The “Home page” is composed of:

- Language selection to access the page with the menus of the device selected (A). Once the language has been selected the Network Parameters page will appear
- Link to the *Datexel social media* (A1)
- Link to the *Datexel web site* “[www.datexel.it](http://www.datexel.it)” (A2) .



The "Network Parameters page" is composed of:

- Indication of the device connected (B).
- Menu selection (B1)
- List of Network Parameters (B2)

**Indication of the device connected (B)**

This label indicates the Order Number of the device connected. It is a parameter common for all of the pages available with the exception of the Home Page therefore it will be described only here.

This parameter doesn't correspond to the Station Name of the device.

**Menu Selection (B1)**

These buttons are common for all of the pages available with the exception of the Home Page therefore they will be described only here.

The green background on the button shows which is the page currently visualized. Mouse click on a button recalls a specific menu.

The list of the menu is the following:

- **Network Parameters:** it shows the main network settings of the device
- **Module Information:** it shows the main information about the device
- **Digital Inputs:** it shows the status of digital inputs, the value of debouncing time and the value of the input counters.
- **Digital Outputs:** it shows the status of digital outputs, Power-up, safe and Watchdog.
- **Home:** allows to go back to the Home Page.

**Network Parameters (B2)**

The list of Parameters shown is the following

- **IP Address:** visualizes the unique IP address value assigned to the device.
- **Subnet Mask:** visualizes the Subnet Mask value assigned to the device.
- **Gateway Mask:** visualizes the Gateway Mask value assigned to the device.
- **Ethernet Port 1 / Ethernet Port 2 :** visualize the status of connection for Ethernet Port 1 and Ethernet Port 2. The status shown are:  
No link: it means there is not a connection sensed on the port indicated.  
100 Mbit: it means there is a connection sensed on the port indicated.
- **MAC address:** visualizes the unique MAC address value of the device

## Module Information

The screenshot displays the 'Module Information' page for a device identified as 'DAT11188PN'. The interface features the Datexel logo and 'PROFINET' branding at the top. A navigation menu on the left includes 'Network Parameters', 'Module Information' (highlighted), 'Digital Inputs', 'Digital Outputs', and 'Home'. The main panel shows the following details:

Parameter	Value
Module Name	dat11188pn
Vendor ID	0x078B
FW Version	1.00.00
Web Version	041024
Vendor Name	Datexel S.r.l.
Module Status	WAIT PROCESS
Protocol	PROFINET IO
PowerUp Event	<span style="color: red;">●</span>
Uptime	0 Days , 00h:23m:32s

A 'Refresh' button is located at the bottom right of the main panel. The website address 'www.datexel.it' is displayed at the bottom of the page.

The "Module Information page" is composed of:

- Indication of the device connected (C).
- Menu selection (C1)
- Overview of the Device main information (C2)
- Button Refresh (C3).

### Information (C2)

- **Module Name:** shows the device name of the device connected. This parameter doesn't correspond to the Station Name of the device.
- **Vendor ID:** shows the unique Vendor ID assigned to Datexel S.r.l. by PI association
- **FW version:** shows the firmware version of the device
- **Web version:** shows the version of the web server
- **Vendor Name:** shows the vendor name (Datexel S.r.l.)
- **Module Status:** shows the current status of the device; refer to section CYCLIC INPUT DATA MAPPING – Bytes 0/1 – System Flags – Supervising Bits for the description of values.
- **Protocol:** shows the communication protocol (PROFINET IO)
- **PowerUp Event:** shows the status of PowerUp bit (red: PowerUp event detected – gray: PowerUp event reset )
- **Uptime:** shows the time elapsed since the moment the device was powered up.

### Refresh (C3)

The button allows to refresh the parameters of this page reading them from the device.

## Digital Inputs

The screenshot shows the 'Digital Inputs' page for a DAT11188PN device. The interface includes a navigation menu (D1) with options like 'Network Parameters', 'Module Information', 'Digital Inputs' (selected), 'Digital Outputs', and 'Home'. The main display area (D2) features a table of digital input channels (Digital In 0-7) with columns for 'Input State' (D3), 'Rise Latch' (D4), 'Fall Latch' (D5), and 'Counter' (D6). A 'Debouncing Time' field (D7) is set to 1 ms. Functional buttons (D8) include 'Read', 'Continuous Reading', and 'Stop'. The interface also displays logos for DATATEXEL, PROFINET, and PROFIBUS/PROFINET, and the website URL www.datexel.it at the bottom.

The "Digital Inputs page" is composed of:

- Indication of the device connected (D).
- Menu selection (D1)
- Column of Digital Inputs (D2)
- Column of Digital Inputs State (D3)
- Column of Digital Inputs Rise Latches (D4)
- Column of Digital Inputs Fall Latches (D5)
- Column of Digital Inputs Counters (D6)
- Debouncing Time (D7)
- Functional buttons (D8)

### Column of Digital Inputs (D2)

Divided by rows per each input shows the status of the digital input channel.

### Column of Digital Inputs State (D3)

Divided by rows per each input shows the status of the digital input (red: Input state 1 – gray: Input state 0).

### Column of Digital Inputs Rise Latches (D4)

Divided by rows per each input shows if a rise latch event for the specific digital input has occurred (checked: event occurred – unchecked: event not occurred).

### Column of Digital Inputs Fall Latches (D5)

Divided by rows per each input shows if a fall latch event for the specific digital input has occurred (checked: event occurred – unchecked: event not occurred).

### Column of Digital Inputs Counters (D6)

Divided by rows per each input shows the value of the counter associated to the specific digital input.

### Debouncing Time (D7)

Shows the value in ms of the Debouncing Time.

### Functional buttons (D8)

Contains the buttons to perform the communication;

Read: single read command sent to the device.

Continuous reading: continuous read command sent to the device.

Stop: stop the reading from the device if a continuous read command has been previously sent.

## Digital Outputs

The screenshot shows the 'Digital Outputs' configuration page for a DAT11188PN device. The interface includes a navigation menu (E1) with options like 'Network Parameters', 'Module Information', 'Digital Inputs', 'Digital Outputs', and 'Home'. The main content area (E2) features a table of digital outputs (0-7) with columns for 'Output State' (E3), 'PowerUp' (E4), and 'Safe' (E5). Below the table, there are checkboxes for 'Short Circuit Alarm' (E6) and 'Watchdog Alarm' (E7), and a 'Watchdog Timeout' field (E8) set to 0 seconds. A 'Refresh' button (E9) is located at the bottom right. The website URL 'www.datexel.it' is displayed at the bottom of the page.

The "Digital Outputs page" is composed of:

- Indication of the device connected (E).
- Menu selection (E1)
- Column of Digital Outputs (E2)
- Column of Digital Outputs State (E3)
- Column of Digital Outputs PowerUp (E4)
- Column of Digital Outputs Safe (E5)
- Short Circuit Alarm (E6)
- Watchdog Alarm (E7)
- Watchdog Timeout (E8)
- Refresh button (E9)

### Column of Digital Outputs (E2)

Divided by rows per each output shows the status of the digital output channel.

### Column of Digital Outputs State (E3)

Divided by rows per each output shows the status of the digital output (red: output activated – gray: output not activated).

### Column of Digital Outputs PowerUp (E4)

Divided by rows per each output shows the setting to which the specific digital output will be forced to when a Powerup event occurs (checked: output will be set to state 1 – unchecked: output will be set to state 0).

### Column of Digital Outputs Safe (E5)

Divided by rows per each output shows the setting to which the specific digital output will be forced to when a Safe event occurs (checked: output will be set to state 1 – unchecked: output will be set to state 0).

### Short Circuit Alarm (E6)

Shows if a Short circuit alarm has occurred (checked: event occurred – unchecked: event not occurred).

### Watchdog Alarm (E7)

Shows if a Watchdog alarm has occurred (checked: event occurred – unchecked: event not occurred).

### Watchdog Timeout (E8)

Shows the value in seconds of the Watchdog Timeout; a value of 0 means that the functionality is disabled.

### Refresh (E9)

The button allows to refresh the parameters of this page reading them from the device.

## ADDITIONAL COMMANDS TO IDENTIFY THE NETWORK IN USE

The following additional commands can be used to identify which network the PC is connected to. To use the following commands, run the Command Prompt (cmd.exe) as Administrator (Pict.1).

### "Ipconfig" command

It is possible to display the networks available on the PC by typing this command and pressing Enter.

The system will return a list of all the PC networks (Pict.2). Before trying to establish a communication with the device, the user must be sure that he is in the correct subnet and network parameters have already been assigned via PROFINET DCP.

### "Ping" command

Once the IP Address has been set, to verify if a device is connected to the network, you can use the "ping" command which is an administration utility for computer networks used to measure the time expressed in milliseconds of one or more packets to reach a network device and return origin.

To use the command type the command "ping" followed by the IP address of the device and press Enter.

Example:


```
ping 192.168.1.100
```

If the device is connected, the system will return the response from the device with the IP address used (Pict.3).

If the system returns the "Destination host unreachable" message, the device is not connected to the network in use.

In this case, it is suggested to check the assignment of the network parameters.

Pict. 1



Pict. 2

```
Administrator: Command Prompt
Microsoft Windows [Version 10.0.18362.418]
(c) 2019 Microsoft Corporation. All rights reserved.

C:\WINDOWS\system32>ipconfig

Windows IP Configuration

Ethernet adapter Ethernet:

   Connection-specific DNS Suffix  . : 
   Link-local IPv6 Address . . . . . : fe80::9c67:4c59:b502:f8c7%7
   IPv4 Address. . . . . : 192.168.1.163
   Subnet Mask . . . . . : 255.255.255.0
   Default Gateway . . . . . : 192.168.1.1

C:\WINDOWS\system32>
```

Pict. 3

```
Administrator: Command Prompt
C:\WINDOWS\system32>ping 192.168.1.100

Pinging 192.168.1.100 with 32 bytes of data:
Reply from 192.168.1.100: bytes=32 time<1ms TTL=100
Reply from 192.168.1.100: bytes=32 time=1ms TTL=100
Reply from 192.168.1.100: bytes=32 time=1ms TTL=100
Reply from 192.168.1.100: bytes=32 time=1ms TTL=100

Ping statistics for 192.168.1.100:
    Packets: Sent = 4, Received = 4, Lost = 0 (0% loss),
    Approximate round trip times in milli-seconds:
        Minimum = 0ms, Maximum = 1ms, Average = 0ms

C:\WINDOWS\system32>ping 192.168.1.123

Pinging 192.168.1.123 with 32 bytes of data:
Reply from 192.168.1.163: Destination host unreachable.
Reply from 192.168.1.163: Destination host unreachable.
Reply from 192.168.1.163: Destination host unreachable.
Reply from 192.168.1.163: Destination host unreachable.


Ping statistics for 192.168.1.123:
    Packets: Sent = 4, Received = 4, Lost = 0 (0% loss),

C:\WINDOWS\system32>
```


## EXAMPLE TO CHECK WINDOWS® CONFIGURATION

This example shows how to change the IP of the Personal Computer (the graphics and the procedure change in relation to the operating system in use) in order to allow the search for the device on the network. To do this a valid IP address must have been assigned to the device via PROFINET DCP.


### 1) Access to Control Panel → *Network and Sharing Center*




### 2) Network and Sharing Center → *Change Adapter Settings*



### 3) Change Adapter Settings → *select the interested network* → *right click* → *Properties*



### 4) Properties → *Internet Protocol version 4* → *Properties*



### 5) Change parameters and click OK.